


ALL NEW 8-INCH WATER MAINS TO BE C900 DR 14 PVC

ALL NEW 2-INCH WATER MAINS TO BE ASTM D-2241 SDR13.5 PVC

ALL WATER AND SEWER INSTALLATION TO BE IN ACCORDANCE WITH THE CITY OF BRYANT  
 "STANDARD SPECIFICATIONS FOR DESIGN AND CONSTRUCTION OF WATER LINES AND SEWER LINES, 2015 EDITION"

EACH WATER SERVICE METER MUST HAVE ITS OWN SERVICE LINE CONNECTION TO THE MAIN (INCLUDES DOUBLE METERS DISPLAYED AS ONE SERVICE LINE ON THE PLAN)



**HOPE CONSULTING**  
 ENGINEERS - SURVEYORS

117 S. Market Street,  
 Benton, Arkansas 72015  
 PH. (501) 315-2626  
 FAX (501) 315-0024  
 www.hopeconsulting.com

---

FOR USE AND BENEFIT OF:  
**JIM AND SANDRA POLLNOW**

**POLLNOW ESTATES**  
 REPLAT AND WATER EXTENSION  
 BRYANT, SALINE COUNTY, ARKANSAS

DATE: 8/8/2019	C.A.D. BY:	DRAWING NUMBER:
REVISED:	CHECKED BY:	18-0328
SHEET: C-30	SCALE:	

500 01S 14W 0 09 200 62 1807

K:\LAND PROJECTS\2018\SURVEYS\2018\18-0328.M & R POLLNOW (COST ESTIMATE)\180328 - POLLNOW ESTATES CIVIL.DWG