

CORRECTION TO THE 2015 ANNUAL DRINKING WATER QUALITY REPORT

Each year, the Arkansas Department of Health prepares Annual Drinking Water Quality Reports for public water providers each year. Bryant's 2015 report was included in the monthly water bill in April 2016. The Department of Health has notified Bryant of a measurement error on the report. As displayed below, the unit of measurement should have been reported in parts per billion (ppb) rather than parts per trillion (ppt) and the allowable Maximum Contaminant Level (MCL) should read 0.2 rather than 200. The correction did not change the compliance status for Bryant's reporting.

SYNTHETIC ORGANIC CONTAMINANTS INCLUDING PESTICIDES AND HERBICIDES						
Contaminant	Violation Y/N	Level Detected	Unit	MCLG (Public Health Goal)	MCL (Allowable Level)	Major Sources in Drinking Water
Benzo(a)pyrene [PAH] (Central Ark. Water)	N	0.03	ppb	0	0.2	Leaching from linings of water storage tanks and distribution lines