



Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone (501) 661-2000

Governor Asa Hutchinson

José R. Romero, MD, Secretary of Health

Engineering Section, Slot 37
www.healthy.arkansas.gov/eng

Ph (501) 661-2623 Fax (501) 661-2032
After Hours Emergency (501) 661-2136

April 5, 2022

Hope Consulting Engineers Surveyors
Mr. William McFadden P.E.
117 S. Market St.
Benton, AR 72015

RE: SUBDIVISION WATER AND SEWER IMPROVEMENTS ENGINEERING PLAN APPROVAL
Cypress Valley Subdivision Ph. 2 (25 Lots) Water and Gravity Sewer Improvements
Lots 24-38, Lots 45, 47-49, Lots 56-60, Lot 124, and Detention Areas Tract A and Tract B
Springwood Circle, Bryant, Saline County (Outside City Limits)
Hope Job Number: 21-0421
ADH Related: 55535 (Under "Magnolia Village Phase II")
ADH Reference No. 118352

Mr. McFadden,

The resubmittal for the project referenced above, received by the ADH Engineering Section online plan submission portal on March 15, 2022, has been reviewed and is hereby approved with the following conditions:

1. The Engineering Section relied upon the statements and representations made in the plans and specifications. In case any statement or representation in the aforementioned documents is found to be incorrect, this Approval may be revoked.
2. There shall be no deviation from the plans and specifications unless revised plans and specifications have been first submitted for review and written consent given.
3. The review and approval of the drawings and specifications were for functional and sanitary features and in no way constitute an analysis of the structural or plumbing design.
4. If construction on this project is not started within one year of the date affixed hereto, this Letter of Approval is void.
5. Construction inspection for this project shall be the responsibility of Hope Consulting Engineers Surveyors.
6. Materials and construction shall be in accordance with the latest edition of the standard specifications and details of the City of Bryant Water and Sewer Utilities.
7. All materials and components installed after January 3, 2014 in drinking water systems are required to comply with the federal definition of "lead free" contained in Public Law 111-380.

When submitting correspondence pertaining to this project, please include the **ADH reference number 118352**.

Sincerely,

A handwritten signature in blue ink that reads "Stephen M. Youngblood".

Stephen M. Youngblood, P.E.
Engineer Supervisor
ADH Engineering Section

SMY: SMR: smr

cc: City of Bryant Utilities (PWS 486)