



**Fwd: Fire approval**

1 message

Truett Smith <tsmith@cityofbryant.com>  
To: Colton Leonard <cleonard@cityofbryant.com>

Fri, Nov 3, 2023 at 9:54 AM

This is the timeframe for this project. They did get a 6 month extension. That puts the deadline at 7/22/24.

----- Forwarded message -----

From: **Thomas Hammond** <thammond@cityofbryant.com>  
Date: Fri, Nov 3, 2023 at 9:46 AM  
Subject: Fwd: Fire approval  
To: Truett Smith <tsmith@cityofbryant.com>

----- Forwarded message -----

From: **Shannon Nuckols** <slaureen.nuckols@gmail.com>  
Date: Fri, Jul 22, 2022 at 1:41 PM  
Subject: Re: Fire approval  
To: Thomas Hammond <thammond@cityofbryant.com>

Thank you!

On Fri, Jul 22, 2022 at 1:27 PM Thomas Hammond <thammond@cityofbryant.com> wrote:  
Mrs. Nuckols,

The purpose of this email is to confirm our conversation we had today, 7/22/22. The topic was using your living room area as a temporary classroom for children 3 to 6 years of age. Temporary in this instance would be a time period of no more than 18 months from the date of this email. In order to use the space discussed @ 4910 Springhill Rd. the following changes shall be made prior to approval.

1. The rear entrance door shall swing in the way of travel (outward) and be equipped with hardware requiring one motion to open.
2. ADA approved ramp shall be installed to service the rear entrance door. Ramp shall be a minimum of 44" in width. If the ramp is elevated it shall require a handrail on both sides.
3. Exits shall be marked with proper signage.
4. Fire Extinguisher shall be provided.
5. Room shall be integrated into existing daycare fire alarm system.
6. An Occupant Load of 15 school age ( > 3) shall be assigned to space.
7. Remove the door going into the mudroom.
8. An inspection from the Fire Marshal and Code Enforcement shall prior to the issue of OC.

On Fri, Jul 22, 2022 at 9:26 AM Shannon Nuckols <slaureen.nuckols@gmail.com> wrote:

Fire Marshall Hammond,  
I just tried to call you and left a message.

On Fri, Jul 22, 2022 at 9:18 AM Shannon Nuckols <slaureen.nuckols@gmail.com> wrote:  
Sorry- It is 501-381-4607. Ill try to call you also.

On Fri, Jul 22, 2022 at 8:46 AM Thomas Hammond <thammond@cityofbryant.com> wrote:  
Mrs. Nuckols,

I have tried calling the # listed below a couple of times. It keeps stating that the call failed. Give me a call and we can discuss further.

On Thu, Jul 21, 2022 at 12:12 PM Shannon Nuckols <slaureen.nuckols@gmail.com> wrote:

Fire Marshall Hammond-  
Could you give me a call when you have a chance? Licensing came out today and said she would approve a space for us and wanted us to call fire department.  
--  
Shannon Nuckols, M.Ed  
Cornerstone Montessori Christian Academy  
[Slaureen.nuckols@gmail.com](mailto:slaureen.nuckols@gmail.com)  
<https://www.cornerstone-montessori-christian.com>  
501-381-4607

--  
**Tommy Hammond**  
**Battalion Chief**  
**Fire Marshal**  
**CFPE**  
Bryant Fire Department

312 Roya Lane  
Bryant, AR 72022  
501-943-0964 Ext. 397 - Office  
501-943-0982 - Fax

--  
Shannon Nuckols, M.Ed  
Cornerstone Montessori Christian Academy  
[Slaureen.nuckols@gmail.com](mailto:Slaureen.nuckols@gmail.com)  
<https://www.cornerstone-montessori-christian.com>  
501-381-4607

--  
Shannon Nuckols, M.Ed  
Cornerstone Montessori Christian Academy  
[Slaureen.nuckols@gmail.com](mailto:Slaureen.nuckols@gmail.com)  
<https://www.cornerstone-montessori-christian.com>  
501-381-4607

--  
**Tommy Hammond**  
**Battalion Chief**  
**Fire Marshal**  
**CFPE**  
Bryant Fire Department  
312 Roya Lane  
Bryant, AR 72022  
501-943-0964 Ext. 397 - Office  
501-943-0982 - Fax

--  
Shannon Nuckols, M.Ed  
Cornerstone Montessori Christian Academy  
[Slaureen.nuckols@gmail.com](mailto:Slaureen.nuckols@gmail.com)  
<https://www.cornerstone-montessori-christian.com>  
501-381-4607



**Tommy Hammond**  
Fire Marshal / Battalion Chief  
City of Bryant

501-943-0964  
[thammond@cityofbryant.com](mailto:thammond@cityofbryant.com)  
[www.cityofbryant.com](http://www.cityofbryant.com)  
312 Roya Lane, Bryant, AR 72022



**Truett Smith, MPA, AICP, PCED**

Community Development Director  
City of Bryant

501-943-0309  
[tsmith@cityofbryant.com](mailto:tsmith@cityofbryant.com)  
[www.cityofbryant.com](http://www.cityofbryant.com)

210 SW 3rd St, Bryant, AR 72022